

Převodní tabulka hranatých kanálků pro externí přívod vzduchu.

Výsledkem je účinný kruhový průměr vznikající v kanále, kterým protéká vzduch.

Pro stanovení požadovaného průměru použijte tabulku pro určení průměru externího přívodu vzduchu.

		Délka strany B (cm)																												
		5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30			
Délka strany A (cm)	5	5	5	6	6	7	7	7	8	8	8	9	9	9	9	10	10	10	10	11	11	11	11	12	12	12	12	12		
	6	5	6	6	7	7	8	8	8	9	9	9	10	10	10	11	11	11	11	12	12	12	12	13	13	13	13	13		
	7	6	6	7	7	8	8	9	9	10	10	10	11	11	11	12	12	12	12	13	13	13	13	14	14	14	14	14		
	8	6	7	7	8	8	9	9	10	10	11	11	11	12	12	12	13	13	13	14	14	14	14	15	15	15	15	15		
	9	7	7	8	8	9	9	10	10	11	11	11	12	12	12	13	13	13	14	14	14	15	15	15	16	16	16	16		
	10	7	8	8	9	9	10	10	11	11	12	12	13	13	13	14	14	14	15	15	15	16	16	16	17	17	17	17		
	11	7	8	9	9	10	10	11	11	12	12	13	13	14	14	14	15	15	16	16	16	17	17	17	18	18	18	18		
	12	8	8	9	10	10	11	11	12	12	13	13	14	14	15	15	16	16	17	17	17	18	18	18	19	19	19	19		
	13	8	9	10	10	11	11	12	12	13	13	14	14	15	15	16	16	17	17	17	18	18	18	19	19	19	20	20		
	14	8	9	10	11	11	12	12	13	13	14	14	15	15	16	16	17	17	18	18	18	19	19	19	20	20	20	20		
	15	9	9	10	11	12	12	13	13	14	14	15	15	16	16	17	17	18	18	19	19	19	20	20	20	21	21	21		
	16	9	10	11	11	12	13	13	14	14	15	15	16	16	17	17	18	18	19	19	20	20	20	21	21	21	22	22		
	17	9	10	11	12	12	13	14	14	15	15	16	16	17	17	18	18	19	19	20	20	21	21	21	22	22	22	23		
	18	9	10	11	12	13	13	14	15	15	16	16	17	17	18	18	19	19	20	20	21	21	22	22	22	23	23	23		
	19	10	11	12	12	13	14	14	15	16	16	17	17	18	18	19	19	20	20	21	21	22	22	23	23	23	24	24		
	20	10	11	12	13	13	14	15	15	16	17	17	18	18	19	19	20	20	21	21	22	22	23	23	24	24	24	24		
	21	10	11	12	13	14	14	15	16	17	17	18	18	19	19	20	20	21	21	22	22	23	23	24	24	25	25	25		
	22	10	11	12	13	14	15	16	16	17	18	18	19	19	20	20	21	21	22	22	23	23	24	24	25	25	26	26		
	23	11	12	13	14	14	15	16	17	17	18	19	19	20	20	21	21	22	22	23	23	24	24	25	25	26	26	26		
	24	11	12	13	14	15	15	16	17	18	18	19	20	20	21	21	22	22	23	23	24	24	25	25	26	26	27	27		
	25	11	12	13	14	15	16	17	17	18	19	19	20	21	21	22	22	23	23	24	24	25	25	26	26	27	27	27		
	26	11	12	13	14	15	16	17	18	18	19	20	20	21	22	22	23	23	24	24	25	25	26	26	27	27	28	28		
	27	12	13	14	15	16	16	17	18	19	19	20	21	21	22	23	23	24	24	25	25	26	26	27	27	28	28	28		
	28	12	13	14	15	16	17	18	18	19	20	20	21	22	22	23	24	24	25	25	26	26	27	27	28	28	29	29		
	29	12	13	14	15	16	17	18	19	19	20	21	22	22	23	23	24	25	25	26	26	27	27	28	28	29	29	29		
	30	12	13	14	15	16	17	18	19	20	20	21	22	22	23	24	24	25	26	26	27	27	28	28	29	29	29	30		

Koleno 90° se počítá jako 2,5 m rovného vedení.